



NATIONAL ELECTRICAL SAFETY BOARD

NKS ATEX Joint Cross Border
Market Surveillance
Campaign on cable glands

Campaign target – Cable glands

- Widely used in many applications
- Plays a major role in safety of installations
- Different sizes and materials



The Campaign

- Schedule: The campaign kicked off in the spring of 2022 and were finalized during autumn of 2023
- Participants: Finland, Norway and Sweden
- In total 18 different products were purchased and tested
- All products tested at same test lab
- Formal requirements checked by MSAs

Sampling

- The MSAs paid special attention to products
 - manufactured in its own country
 - the importer of products was located to its country
- Only d, e and t protection
- Sizes limited to M20 and M40

Formal requirements - Traceability

Table 1 – Compliance with traceability requirements

Requirement of traceability	Number checked	Number compliant	Compliance (%)
Identification requirements (type designation)	18	14	77
Name of the manufacturer	18	14	77
Address of the manufacturer	18	1	5
Name of the importer (if needed)	-		
Address of the importer (if needed)	-		

Formal requirements - CE marking

Table 2 – Compliance with requirements of the CE marking

Requirement of CE marking	Number checked	Number compliant	Compliance (%)
CE-mark affixed	18	14	94
Layout of CE marking	17	14	82
Height of CE marking	17	0	0
NB number	17	17	100

Formal requirements – ATEX markings

Table 3 – Compliance with ATEX markings

Requirement of traceability	Number checked	Number compliant	Compliance (%)
Year of construction	18	4	22
Specific marking of explosion protection (, equipment group and category)	18	12	66
Letter ‘G’ and/or the letter ‘D	18	12	66
Other essential safety use marking	18	10	56

Formal requirements - DoC

Table 4 – Compliance with DoC requirements

Number of EUT assessed	DoC available	DoC not made available	DoC with no issues found	Overall DoC compliance (%) *
18	17	1	10	56

Formal requirements – Language requirements

Table 6 – Compliance with language requirements of instructions

Number assessed	Compliant Manual	Overall instruction compliance (%)
18	4	22

Testing - Resistance to impact test

Table 7 – Compliance with Resistance to impact test

Type of product	Number checked	Number compliant	Compliance (%)
Metal cable gland (M20)	6	6	100
Plastic cable gland (M20)	5	0	0
Plastic cable gland (M40)	2	2	100
Blanking element (M20/M40)	4	4	100

Testing – Visual IP test

Table 8 – Findings of Visual IP test

Findings	Number of findings
No issues found	7
Sample was provided with a flat gasket, but instructions did not specify tolerance for the clearance hole, likely not an issue due to large margin in flat gaskets	2
Sample was provided with an O-ring, but instructions did not specify tolerance for the clearance hole	4
Sample did not have any gasket, but the instructions mention a specific gasket is required for dust applications according to EN 60079-31:2014	1
Sample did not have any gasket and the instructions do not mention a gasket needs to be used in dust applications according to EN 60079-31:2014	3

Testing - Instructions

Table 9 – Compliance with Instructions requirements

Instructions requirement	Number compliant	Compliance (%)
Minimum and maximum diameter of the cable of circular cables	17	100
Minimum and maximum dimensions of non-circular and metal-sheathed cables	N/A	N/A
Tightening process of the compression element, including the tightening torque (only gable glands)	11	85
For compound-filled glands, details on the installation of the filling compound	N/A	N/A
For compound-filled glands, the maximum diameter over cores of the cable that the gland is intended to accept and the maximum numbers of cores that can pass through the compound	N/A	N/A

Testing – Instructions

Table 9 – Compliance with Instructions requirements

For entries into enclosures: Threaded entries		
Thread size	15	88
Tolerance class	5	29
Enclosure material limitations	14	82
Enclosure interface sealing method	14	82
Maximum surface roughness of the enclosure face for sealing	4	24
Thickness range of the enclosure wall (minimum)	8	47
Thickness range of the enclosure wall (maximum)	3	18
Perpendicularity	5	29
Permitted use and location of any earth tags	-	
For entries into enclosures: Clearance holes		
Hole dimensions, including tolerance	9	53
Enclosure material limitations	N/A	N/A
Thickness range of the enclosure wall (minimum)	7	41
Thickness range of the enclosure wall (maximum)	3	18
Enclosure interface sealing method	14	82
Maximum surface roughness of the enclosure face for sealing	4	24
Perpendicularity	5	29
Cable gland securing details	15	88
Permitted use and location of any earth tags	-	

Findings

- Only 56 % of the products had a correct Declaration of Conformity.
- 78 % of the products lacked instructions of use in correct language. This means that the installer may not fully understand how to install and use the gland safely.
- No plastic cable glands of smaller size (M20) passed the impact test. The reason could be to the lack of correct instructions.
- Lack of clear instructions on how to mount and use the glands in different applications, with or without gasket.

Conclusions

- The manufacturer needs to ensure that sufficient instructions of use, in the correct language is to be supplied with the product. Otherwise, the product cannot be used safely.
- The installer must be observant and read the user instructions of use carefully. It is easy to miss a needed gasket or any other detail that can make a big impact on the overall safety of the electrical installation. If instructions are missing, the electrician must report this to the manufacturer.
- There are some unclear issues with what the directive states as needed in instructions, the standard and Notified bodies. These differences are to be discussed further between the involved parties.

For more information

- Finnish Safety and Chemicals Agency (Tukes)
Hanna Mustonen
hanna.mustonen@tukes.fi
- Directorate for Civil Protection (DSB)
Bjørn Nyrud
bjorn.nyrud@dsb.no
- Elsäkerhetsverket
Martin Gustafsson
martin.gustafsson@elsakerhetsverket.se